



# NOTES:

- 1. FOR NEW CONSTRUCTION AND REHABILITATION WORK, JPB OWNED FIBER OPTIC SHALL BE UTILIZED FOR STATION INTERFACE.
- 2. REFER TO DRAWING SD-4834 FOR 24F CABLE TERMINATION.
- 3. SPECIFIC STATION DESIGN WILL DETERMINE THE QUANTITY OF DISTRIBUTION CABINETS. THE BACKBONE FIBER OPTIC CABLE SHALL BE A PHYSICALLY DIVERSE RING TOPOLOGY.
- 4. SEPARATE VIRTUAL LANS OF AT LEAST 100MB SHALL BE PARTITIONED FOR EACH TYPE OF SUBSYSTEM.
- 5. ACTUAL QUANTITY OF SUBSYSTEM DEVICES SHALL BE BASED ON SPECIFIC STATION DESIGN.
- 6. CID NETWORK DEVICES WILL BE SUPPLIED AND PROGRAMMED BY CLIPPER.



0	10126		FIFTH EDITION			
						•
						ı
						H






STATION COMMUNICATIONS OVERALL SYSTEM DESCRIPTIONS CAM, CID, TVM AND VMS SYSTEMS PHYSICAL DISTRIBUTION TOPOLOGY


**ENGINEERING STANDARD DRAWINGS** SD-4105 EDITION: FIFTH SCALE: STANDARD DRAWING NO.: SD-4105

# PLATFORM 1 CID LAN SUBSYSTEM



- 1. PHYSICAL SINGLE MODE FIBER OPTIC NETWORK TIES MAIN AND DISTRIBUTION SWITCH AND EACH CID DEVICE (STAR TOPOLOGY).
- 2. ACTUAL QUANTITY OF CID EQUIPMENT DEPENDS ON SPECIFIC STATION LOCATION AND DESIGN.
- 3. CLIPPER TO PROVIDE THE CID ROUTER, CID MAIN AND DISTRIBUTION SWITCHES, 24V DC POWER SUPPLIES AND CID DEVICES. CLIPPER TO TERMINATE CID DEVICES ON POLES FOR CID NETWORK AND PROVIDE ALL INTERCONNECTING CONDUIT AND COMMUNICATIONS/POWER WIRING. CALTRAIN TO FURNISH CID POLES AND TEMPORARY COVERS FOR INSTALLATION BY THE CONTRACTOR.
- 4. EACH CID DEVICE SHALL HAVE A DEDICATED AND PROTECTED 24VDC POWER CIRCUIT FROM THE DC CABINET.

						PENINSULA CORRIDOR JOINT	POWERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE	NAME: SD-4106
10126 DATE BY	FIFTH EDITION  Y CHK APP	DESCRIPTION	REV	DATE BY	CHK A	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	1-PLATFORM CID LAN SUBSYSTEM	REV: SCALE: STANDARD	EDITION: FIFTH  NTS  DRAWING NO.: SD-4106



FIFTH EDITION

DESCRIPTION

REV DATE BY CHK APP

010126

DATE BY CHK APP


SCALE:

STANDARD DRAWING NO.:

SD-4107

CID • • • CID MULTIPLE DEVICES


JPB F.O. NETWORK




# PLATFORM 1 CID LAN SUBSYSTEM

- 1. PHYSICAL SINGLE MODE FIBER OPTIC NETWORK TIES MAIN AND DISTRIBUTION SWITCH LOCATIONS (2 STRANDS OF FIBER PER LINK).
- 2. HOME RUN COMMUNICATIONS CAT 6A OR FO CABLE BETWEEN DISTRIBUTION SWITCH AND EACH ASSOCIATED CID DEVICE.
- 3. ACTUAL QUANTITY OF SHOWN DEVICES DEPENDS ON SPECIFIC STATION LOCATION AND DESIGN.
- 4. FOR CLARITY, INTERMEDIATE CROSS—CONNECT PATCH—PANEL EQUIPMENT AND CORDS ARE NOT SHOWN.
- 5. EACH CID DEVICE SHALL HAVE DEDICATED AND PROTECTED 24 VDC POWER CIRCUIT FROM THE DC CABINET.

	PENINSULA CORRIDOR JOINT POV	WERS BOARD	<b>ENGINEERING STANDARD DRAWINGS</b>	CADD FILE NAME: SD-4108
O10126	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	STATION COMMUNICATIONS OVERALL SYSTEM DESCRIPTIONS 1-PLATFORM CID LAN SUBSYSTEM PHYSICAL TOPOLOGY	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4108






### NOTE:


PLATFORM SPEAKERS SHALL BE WIRED IN A MANNER SUCH THAT NO TWO ADJACENT SPEAKERS ARE ASSIGNED THE SAME AMPLIFIER.

								PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4110
R	010126 EV DATE	ву снк	FIFTH EDITION	DESCRIPTION	REV DATE	BY CHK	APP	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	1-PLATFORM PA SYSTEM	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4110




- 1. PLATFORM SPEAKERS SHALL BE WIRED IN A MANNER SUCH THAT NO TWO ADJACENT SPEAKERS ARE ASSIGNED THE SAME AMPLIFIER.
- 2. PLATFORM 1 AND PLATFORM 2 SPEAKERS SHALL BE TERMINATED ON TWO SEPARATE OUTPUTS.

	PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4111
O10126 FIFTH EDITION  REV DATE BY CHK APP  DESCRIPTION  REV DATE BY CHK APP	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain <sub>®</sub>	2-PLATFORM PA SYSTEM	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4111





							PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FIL	ILE NAME: SD-4112
REV	010126 date	BY CHK	FIFTH EDITION  APP	DESCRIPTION	REV DATE I	BY CHK APP	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	CCTV SYSTEM	REV: SCALE: STANDAR	EDITION: FIFTH  NTS  RD DRAWING NO.: SD-4112


- REFERENCE ANSI/TIA/EIA 568, COMMERCIAL BUILDING TELE— COMMUNICATIONS CABLING STANDARD.
- 2. WA (WORK AREA) CAN BE ANY NETWORK DEVICE SUCH AS: VMS, TVM, CCTV, CID OR DATA OUTLET.
- 3. EACH UTP CABLE SHALL BE PROTECTED AT THE ENTRANCE OF THE DC OR CER BY USE OF APPROPRIATE SURGE / LIGHTNING PROTECTOR.




	PENINSULA CORRIDOR JOINT	POWERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4113
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	NETWORK CABLE DISTRIBUTION	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4113













**ELEVATION** 

					PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	
010126	6 BY CHK	FIFTH EDITION	DESCRIPTION	BY CHK	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain <sub>®</sub>	TVM SUBSYSTEM	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4401









	DENINGULA CORRIDOR JOINT ROWERO ROARD	ENGINEEDING OTANDADD DDANAUNGO CADD FILE NAME:
	PENINSULA CORRIDOR JOINT POWERS BOARD	ENGINEERING STANDARD DRAWINGS SD-4501
	APPROVED BY:	FIBER OPTIC OUTSIDE PLANT (OSP)    REV:   EDITION:   FIFTH
	Bin Zhang Cal Train.	FIBER OPTIC CABLE NTS
O10126   FIFTH EDITION   REV DATE BY CHK APP   DESCRIPTION   REV DATE BY CHK APP	DIRECTOR, ENGINEERING	CONFIGURATION DETAILS  STANDARD DRAWING NO.: SD-4501

ALTOS® Loose Tube, Gel-Free Cable 12 F, Single-mode (OS2) or equivalent

General Specifications								
Installation Methods	Aerial, Duct							
Cable Type	Loose Tube							
Environment	Outdoor							
Product Type	Dielectric							
Fiber Category	Single-mode (OS2)							
Cable geometry	Round							

Standards	
RoHS	Free of hazardous substances according to RoHS 2011/65/EU
Common Installations	Outdoor lashed aerial and duct, indoor when installed according to National Electrical Code® (NEC®) Article 770
Design and Test Criteria	ANSI/ICEA S-87-640


Environmental Conditions								
Notes	Corning recommends storing cable in a proper temperature environment prior to installation to allow the cable temperature to meet installation temperature range specifications for best installation results.							
Temperature Range, Installation	-30 °C to 70 °C (-22 °F to 158 °F )							
Temperature Range, Operation	-40 °C to 70 °C (-40 °F to 158 °F )							
Temperature Range, Storage	-40 °C to 70 °C (-40 °F to 158 °F )							


Cable Design	
Central Element	Dielectric
Fiber Count	12
Number of Ripcords	1
Outer Jacket Color	Black
Outer Jacket Material	Polyethylene (PE)

Cable Design		
Buffer Tube Color	Blue	
Buffer Tube Diameter	2.5 mm (0.1 in)	
Number of Active Tubes	1	
Number of Filling Elements	5	
Number of Tube Positions	6	
Таре	Water-swellable	
Fiber Coloring	Blue, Orange, Green, Brown, Slate, White, Red, Black, Yellow, Violet, Rose, Aqua	
Fibers per Tube	12	
Color Code Standards	Telcordia	

Mechanical Specifications	
Max. Tensile Strength, Long-Term	890 N (200.08 lbf)
Max. Tensile Strength, Short-Term	2700 N (606.98 lbf)
Nominal Outer Diameter	10.5 mm (0.41 in )
Min. Bend Diameter Installation	316 mm (12.44 in)
Min. Bend Diameter Operation	210 mm (8.27 in)

Optical Characteristics		
Fiber Code	Е	
Performance Option Code	01	
Fiber Category	OS2	
Fiber Type	Single-mode (OS2) / 250 μm	
Fiber Name	Single-mode (OS2)	
Maximum Attenuation	0.4 dB/km / 0.4 dB/km / 0.3 dB/km	
Wavelengths	1310 nm / 1383 nm / 1550 nm	
Fiber Compliance	ITU-T G.652.D	





	PENINSULA CORRIDOR JOINT POWERS BOAI	RD ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4503
	APPROVED BY:	FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH
	Oin Thang Cal	ALTOS GEL-FREE DOUBLE-JACKET	SCALE: NTS
010126 FIFTH EDITION		DIELECTRIC CABLES,	STANDARD DRAWING NO.:
REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	DIRECTOR, ENGINEERING	12-288 FIBERS	SD-4503

General Specifications	
Installation Methods	Aerial, Duct
Cable Type	Loose Tube
Environment	Outdoor
Product Type	Dielectric
Fiber Category	Single-mode (OS2)
Cable geometry	Round

Standards	
RoHS	Free of hazardous substances according to RoHS 2011/65/EU
Common Installations	Outdoor lashed aerial and duct, indoor when installed according to National Electrical Code® (NEC®) Article 770
Design and Test Criteria	ANSI/ICEA S-87-640


Environmental Conditions	
Notes	Corning recommends storing cable in a proper temperature environment prior to installation to allow the cable temperature to meet installation temperature range specifications for best installation results.
Temperature Range, Installation	-30 °C to 70 °C (-22 °F to 158 °F )
Temperature Range, Operation	-40 °C to 70 °C (-40 °F to 158 °F )
Temperature Range, Storage	-40 °C to 70 °C (-40 °F to 158 °F )

Cable Design	
Central Element	Dielectric
Fiber Count	24
Number of Ripcords	1
Outer Jacket Color	Black
Outer Jacket Material	Polyethylene (PE)


Cable Design		
Buffer Tube Color	Blue, Orange	
Buffer Tube Diameter	2.5 mm (0.1 in)	
Number of Active Tubes	2	
Number of Filling Elements	4	
Number of Tube Positions	6	
Таре	Water-swellable	
Fiber Coloring	Blue, Orange, Green, Brown, Slate, White, Red, Black, Yellow, Violet, Rose, Aqua	
Fibers per Tube	12	
Color Code Standards	Telcordia	

Mechanical Specifications	
Max. Tensile Strength, Long-Term	890 N (200.08 lbf)
Max. Tensile Strength, Short-Term	2700 N (606.98 lbf)
Nominal Outer Diameter	10.5 mm (0.41 in )
Min. Bend Diameter Installation	316 mm (12.44 in)
Min. Bend Diameter Operation	210 mm (8.27 in)

Optical Characteristics		
Fiber Code	E	
Performance Option Code	01	
Fiber Category	OS2	
Fiber Type	Single-mode (OS2) / 250 μm	
Fiber Name	Single-mode (OS2)	
Maximum Attenuation	0.4 dB/km / 0.4 dB/km / 0.3 dB/km	
Wavelengths	1310 nm / 1383 nm / 1550 nm	
Fiber Compliance	ITU-T G.652.D	



ALTOS® Loose Tube, Gel-Free Cable, 24 F, Single-mode (OS2)



	PENINSULA CORRIDOR JOINT POW	PENINSULA CORRIDOR JOINT POWERS BOARD		CADD FILE NAME: SD-4504	
	APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH	
010126 FIFTH EDITION	Din Thang	Caltrain <sub>®</sub>	ALTOS LOOSE TUBE, GEL—FREE, DOUBLE—JACKET 24 F,	SCALE:  NTS  STANDARD DRAWING NO.:	
REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	DIRECTOR, ENGINEERING		SINGLE-MODE (OS2)	SD-4504	

General Specifications	
Installation Methods	Aerial, Duct
Cable Type	Loose Tube
Environment	Outdoor
Product Type	Dielectric
Fiber Category	Single-mode (OS2)
Cable geometry	Round

Standards					
RoHS	Free of hazardous substances according to RoHS 2011/65/				
Common Installations	Outdoor lashed aerial and duct, indoor when installed according to National Electrical Code® (NEC®) Article 770				
Design and Test Criteria	ANSI/ICEA S-87-640				


<b>Environmental Conditions</b>	
Notes	Corning recommends storing cable in a proper temperature environment prior to installation to allow the cable temperature to meet installation temperature range specifications for best installation results.
Temperature Range, Installation	-30 °C to 70 °C (-22 °F to 158 °F )
Temperature Range, Operation	-40 °C to 70 °C (-40 °F to 158 °F )
Temperature Range, Storage	-40 °C to 70 °C (-40 °F to 158 °F )


Cable Design	
Central Element	Dielectric
Fiber Count	72
Number of Ripcords	1
Outer Jacket Color	Black
Outer Jacket Material	Polyethylene (PE)

Cable Design	
Buffer Tube Color	Blue, Orange, Green, Brown, Slate, White
Buffer Tube Diameter	2.5 mm (0.1 in)
Number of Active Tubes	6
Number of Tube Positions	6
Таре	Water-swellable
Fiber Coloring	Blue, Orange, Green, Brown, Slate, White, Red, Black, Yellow, Violet, Rose, Aqua
Fibers per Tube	12
Color Code Standards	Telcordia


Mechanical Specifications	
Max. Tensile Strength, Long-Term	890 N (200.08 lbf)
Max. Tensile Strength, Short-Term	2700 N (606.98 lbf)
Nominal Outer Diameter	10.5 mm (0.41 in )
Min. Bend Diameter Installation	316 mm (12.44 in)
Min. Bend Diameter Operation	210 mm (8.27 in)

Optical Characteristics	
Fiber Code	Е
Performance Option Code	00
Fiber Category	OS2
Fiber Type	Single-mode (OS2) / 250 μm
Fiber Name	Single-mode (OS2)
Maximum Attenuation	0.35 dB/km / 0.35 dB/km / 0.25 dB/km
Wavelengths	1310 nm / 1383 nm / 1550 nm
Fiber Compliance	ITU-T G.652.D






	PENINSULA CORRIDOR JOINT POV	VERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4505
	Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  ALTOS LOOSE TUBE, GEL-FREE,	REV: EDITION: FIFTH  SCALE: NTS
O10126	DIRECTOR, ENGINEERING		DOUBLE-JACKET 72 F, SINGLE-MODE (OS2)	STANDARD DRAWING NO.: SD-4505





# 12 STRAND PRE-TERMINATED SINGLE-MODE FIBER OPTIC CABLE ASSEMBLY

- 1. THE OPTICAL CONNECTOR SHALL MEET MECHANICAL AND ENVIRONMENTAL PERFORMANCE TIA/EIA-568-C.3 SPECIFICATIONS.
- 2. THE CABLE ASSEMBLY SHALL BE EQUIPPED WITH A PULLING KIT.
- 3. THE CABLE ASSEMBLES SHALL COME IN VARYING LENGTHS FROM 50 TO 200 FEET DEPENDING ON THE DISTANCE FROM THE DESIGNATED SPLICE CLOSURE TO THE FIBER DISTRIBUTION PANEL.
- 4. MANUFACTURER: CORNING PART # OOM112EB4DIE200F-P OR APPROVED EQUIVALENT.

					PENINSULA CORRIDOR JOINT POWERS BOARD ENGINEERING STANDARD DRAWINGS [ca	SD-4506
					APPROVED BY:  SING TABLE 1.00  FIBER OPTIC OUTSIDE PLANT (OSP)  SCORE 1.00  FIBER OPTIC OUTSIDE PLANT (OSP)  SCORE 1.00  FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH SCALE:
	010126	FIFTH EDITION			PRE-TERMINATED FOR DOOR ASSEMBLY	NTS
REV	DATE BY	CHK APP	DESCRIPTION	REV DATE BY CHK APP	DIRECTOR, ENGINEERING	SD-4506







# OUTSIDE PLANT CABLE PULLING OPERATION


#### NOTES:


- 1. CARE MUST BE TAKEN. FIBER OPTIC CABLE IS SENSITIVE TO EXCESSIVE PULLING, BENDING AND CRUSH FORCES. ANY SUCH DAMAGE MAY ALTER THE CABLE'S CHARACTERISTICS TO THE EXTENT THAT THE CABLE SECTION MAY HAVE TO BE REPLACED. TO ENSURE ALL SPECIFICATIONS HAVE BEEN MET, CONSULT THE SPECIFIC CABLE SPECIFICATION SHEET FOR THE CABLE YOU ARE INSTALLING.
- 2. THE FOLLOWING MAY BE USED AS A GENERAL GUIDELINE FOR INSTALLING FIBER OPTIC CABLE: MAXIMUM PULLING TENSION: 2700 N (600 LBS).
- 3. ALL CABLES UP TO (0.9 IN) NOMINAL CABLE DIAMETER CAN BE INSTALLED USING A (20 IN) DIAMETER WHEEL. TABLE 1 PROVIDES COMPLETE MINIMUM BEND RADIUS INFORMATION.
- 4. WHEN PLACING FIBER OPTIC CABLE IN HDPE DUCT, THE "FILL RATIO" OF THE HDPE DUCT SHALL NOT EXCEED 50%.
- 5. AFTER PLACEMENT, ALL HDPE DUCT MUST BE CAPPED OR PLUGGED TO PREVENT MOISTURE OR FOREIGN MATTER FROM ENTERING UNTIL THE CABLE INSTALLATION BEGINS.
- 6. CABLE PULLING MEDIA SHALL CONSIST OF ARAMID YARD MULE TAPE AND / OR PULL ROPES.
- 7. CONTRACTOR SHALL VERIFY AND DOCUMENT ALL LENGTH MARKING OF CABLE AT EACH SPLICE POINT AND/OR SPLICE BOX.
- 8. ALL CABLE SLACK SHALL BE STORED ON SIDE WALLS OR BOTTOM OF ALL SPLICE BOXES. (SEE "TYPICAL FIBER OPTIC CONNECTIVITY PROCESSES").
- 9. AT SPLICE POINTS, PULL SUFFICIENT LENGTH (150 FT) OF SLACK FROM THE LIP OF THE SPLICE BOX). THIS ALLOWS FOR CLOSURE PREPARATION AND SPLICING TO BE PERFORMED AT STREET LEVEL.
- 10. A PULLING GRIP IS NECESSARY TO SECURE THE PULLING TO THE STRENGTH MEMBERS OF THE CABLE. PULLING DRIPS SHALL BE FIELD INSTALLED.
- 11. THE USE OF A SWIVEL IS REQUIRED TO PREVENT THE PULL LINE FROM IMPAIRING A TWIST TO THE CABLE AS IT IS PULLED THROUGH THE HDPE DUCT. A "BREAK—AWAY" SWIVEL SHALL BE REQUIRED WHEN PULLING MACHINERY IS BEING USED. SWIVEL SHALL BE SET AT A MAX OF 2700 N.
- 12. IT IS RECOMMENDED THAT MECHANICAL PULLING EQUIPMENT BE UTILIZED ON ALL PULLS UP TO 600 METERS (2000 FT). HAND PULLS SHALL ONLY BE ALLOWED WHEN TOTAL LENGTH OF PULL IS A MAXIMUM LENGTH OF (550 FT).
- 13. THE FOLLOWING BEND RADIUS SHALL BE MAINTAINED AT ALL TIME: (SEE TABLE 1).


# TABLE 1

NOMINAL CABLE DIAMETER MM/(INCHES)	MINIMUM BEND RADIUS (NO TENSION) INSTALLED CM (INCHES)	MINIMUM BEND RADIUS (UNDER TENSION) CM (INCHES)
6 -10 (1/4 -3/9)	10.0 ( 4.0)	15.0 ( 6.0)
10.1-15 (4/10-6/10)	15.0 ( 6.0)	22.5 ( 9.0)
15.1-20 (10/16-8/10)	20.0 ( 8.0)	25.0 (10.0)
20.1-23 (13/16-9/10)	23.0 ( 9.0)	25.0 (10.0)
23.1-25 (15/16-1.0)	25.0 (10.0)	30.0 (12.0)

								PENINSULA CORRIDOR JOINT POV	VERS BOARD	<b>ENGINEERING STANDARD DRAWINGS</b>	
								Bin Zhana	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH SCALE:
REV	010126	BY CHK	FIFTH EDITION	DESCRIPTION	REV DA	TE BY	( CHK	DIRECTOR, ENGINEERING	Galualle	FIBER OPTIC CABLE PULL METHOD	NTS  STANDARD DRAWING NO.:  SD-4508










FIGURE 4-LOOSE BUFFER TUBE STORAGE

FIGURE 1-CLOSURE SHELL

FIGURE 2-FOUR PORT END PLATE

FIGURE 3-BLANK END PLATE

1. TORQUE BAR

A=1" DIAMETER B=1-1/4" DIAMETER

2. TORQUE BAR BRACKETS

1. END PLATE

2. RETAINER BRACKETS


3. SPLICE TRAY HOLD DOWN STRAPS


3-SECTION END PLATE

FIGURE 5-LOADED SPLICE CLOSURE

- 1. THE CONTRACTOR SHALL FOLLOW ALL MANUFACTURER'S INSTRUCTIONS AND PROCEDURES FOR THE CABLE AND SPLICE CLOSURE INSTALLATION.
- 2. ALL EXPRESSED (NO SPLICE) BUFFER TUBES SHALL BE SECURED AND STORED INSIDE THE CLOSURE.
- 3. ONCE SPLICING IS COMPLETE AND TRAYS AND BUFFER TUBES ARE SECURED, THE CLOSURE SHALL BE SEALED AND TORQUED TO PRODUCT SPECIFICATIONS.
- 4. THE SEALED CLOSURE SHALL BE MOUNTED ON RACKS WITHIN THE SPLICE BOX OR MAN HOLE ACCORDING TO THE CONSTRUCTION DRAWINGS.
- 5. MANUFACTURER: TYCO, OR APPROVED EQUIVALENT.


		PENINSULA CORRIDOR JOINT POV	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4509
		APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH
010126 FIFTH EDITION		Oin Thang	Caltrain	CONDUIT LAYOUT TYPICAL FIBER OPTIC SPLICE CLOSURE	NTS STANDARD DRAWING NO.:
REV DATE BY CHK APP DESCRIPTION REV DATE	HK APP	DIRECTOR, ENGINEERING			SD-450





#### TYPICAL F/O STANDARD SPLICE TRAY - BUTT SPLICE

- 1. THE CONTRACTOR SHALL FOLLOW ALL MANUFACTURER'S INSTRUCTION AND PROCEDURES FOR THE CABLE AND SPLICE ENCLOSURE INSTALLATION.
- 2. ALL BUFFER TUBES SHALL BE CUT TO THE SAME LENGTH WITH THE PROPER STORAGE SLACK AND SECURED TO THE TRAY BY TIE WRAPS OR MANUFACTURER'S APPROVED EQUAL.
- 3. ALL FIBERS SHALL BE CUT TO FIT IN THE ASSIGNED SPLICE POSITION WITH THE PROPER AMOUNT OF SLACK.
- 4. ALL SPLICES SHALL HAVE HEAT SHRINK SPLICE PROTECTORS AND SHALL BE SECURED IN THE ASSIGNED HOLDER POSITION.
- 5. NO MORE THAN THREE BUFFER TUBES, 36 FIBERS, SHALL BE SPLICED IN ANY SPLICE TRAY RATED FOR 36 FIBERS OR LESS.




#### TYPICAL F/O HEAT SHRINK SPLICE PROTECTOR

- 1. ALL HEAT SHRINK SPLICE PROTECTORS SHALL BE TESTED TO BELLCORE (TELCORDIA) SPEC GR 1380 AND BE 60mm IN LENGTH.
- 2. ALL SPLICE PROTECTORS SHALL HAVE A CLEAR POLYLEFIN TUBE, AN INNER COPOLYMER DIELECTRIC SLEEVE AND A STAINLESS STEEL STRENGTH MEMBER.
- 3. THE SHRINK PROCESS MAY VARY IN TIME AND TEMPERATURE. THE DIAMETER OF THE COMPLETE SHRINK SLEEVE PROTECTOR SHALL BE 2.8mm.
- 4. ALL SPLICE PROTECTORS SHALL BE SECURED TO THE TRAY BY MEANS OF A NON-HARDENING SILICONE ADHESIVE APPLIED TO THE INSTALLED SPLICE IN THE SPLICE TRAY HOLDER.

#### TYPICAL F/O STANDARD SPLICE TRAY - DROP CABLE/PATCH CORD (EXPRESS)


- 1. THE CONTRACTOR SHALL FOLLOW MANUFACTURER'S INSTRUCTIONS AND PROCEDURES FOR THE CABLE AND SPLICE CLOSURE INSTALLATION.
- 2. ALL EXPRESSED (NO SPLICE) BUFFER TUBES SHALL BE SECURED AND STORED INSIDE CLOSURE.
- 3. ALL NON-EXPRESSED (SPLICED) FIBERS SHALL HAVE HEAT SHRINK SPLICE PROTECTORS INSTALLED OVER THE SPLICE.
- 4. ALL NON-EXPRESSED FIBERS (SPLICED) SHALL BE CUT TO THE PROPER LENGTH AND SECURED IN THE ASSIGNED SPLICE HOLDER.
- 5. ALL EXPOSED NON-EXPRESSED FIBERS SHALL BE STORED PROPERLY INSIDE SPLICE TRAY TO ENSURE MAXIMUM PROTECTION FROM DAMAGE.
- 6. THE DROP CABLE AND/OR PIG TAIL SHALL BE PROPERLY SECURED INSIDE THE SPLICE TRAY WITH TIE WRAPS OR MANUFACTURER'S APPROVED EQUAL.
- 7. MANUFACTURER: TYCO OR APPROVED EQUIVALENT

					PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4510
					Bin Zhang	Calirain	FIBER OPTIC OUTSIDE PLANT (OSP)  TYPICAL FIBER OPTIC SPLICE TRAY	REV: EDITION: FIFTH SCALE:
RF	01012 / DATE	FIFTH EDITION  APP DESCRIPTION	REV DATE	BY CHK	DIRECTOR, ENGINEERING		TIPICAL FIDER OPTIC SPLICE TRAT	STANDARD DRAWING NO.: SD-4510




# ASSEMBLY CCH-CS12







FRONT



CCH PIGTAILED CASSETTE







- EACH PIGTAILED SPLICE CASSETTE SHALL CONSIST OF 12 SC/UPC DUPLEX TERMINATIONS.
- 2. THE SPLICE TRAY SHALL RESIDE WITHIN THE CASSETTE.
- 3. THE PIGTAILED SPLICE CASSETTE SHALL BE INSTALLED WITHIN THE ASSIGNED FDP PANEL SLOT.
- 4. THE PIGTAILED SPLICE CASSETTE SHALL BE INSTALLED ACCORDING TO THE MANUFACTURER'S PROCEDURES AND SPECIFICATIONS.
- 5. MANUFACTURER SHALL BE CORNING OR APPROVED EQUIVALENT. PART # CCH-CS12-59-POORE.

	PENINSULA CORRIDOR JOINT POW	VERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4512
	Bin Zhang	Calirain	FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH  SCALE:
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	DIRECTOR, ENGINEERING		PIGTAILED SPLICE CASSETTE	STANDARD DRAWING NO.: SD-4512


# CCH-01U 3" PROJECTION (MOUNTING BRACKET SHIFTED FORWARD FOR 3" PROJECTION)


REAR VIEW












FIBER DISTRIBUTION PANEL


- 1. FIBER DISTRIBUTION PANEL SHALL ACCOMMODATE 24 FIBER OPTIC TERMINATIONS
- THE OUTSIDE DROP CABLE SHALL BE SPLICED TO THE PIGTAILED CASSETTES. THE PIGTAILED CASSETTES SHALL RESIDE IN THE FDP HOUSING.
- 3. THE FIBER DISTRIBUTION PANEL SHALL BE INSTALLED ACCORDING TO THE MANUFACTURER'S PROCEDURES AND SPECIFICATIONS.
- 4. MANUFACTURER SHALL BE CORNING OR APPROVED EQUIVALENT. PART # CCH-01U (24 POSITION) RESIDING AT EACH CER


									PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4513
									Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  24 POSITION FO DISTRIBUTION PANEL	REV: EDITION: FIFTH  SCALE: NTS
RE	010126 / DATE	BY CHK	FIFTH EDITION  APP	DESCRIPTION	REV	DATE	BY CHK	APP	DIRECTOR, ENGINEERING		RACK MOUNT	STANDARD DRAWING NO.: SD-4513


# CCH-01U 3" PROJECTION (MOUNTING BRACKET SHIFTED FORWARD FOR 3" PROJECTION)


REAR VIEW












FIBER DISTRIBUTION PANEL

- 1. FIBER DISTRIBUTION PANEL SHALL ACCOMMODATE 12 FIBER OPTIC TERMINATIONS
- 2. THE PRE-TERMINATED DROP SHALL TERMINATE WITHIN THE PANEL.
- 3. THE FIBER DISTRIBUTION PANEL SHALL BE INSTALLED ACCORDING TO THE MANUFACTURER'S PROCEDURES AND SPECIFICATIONS.
- 4. MANUFACTURER SHALL BE CORNING OR APPROVED EQUIVALENT. PART # CCH-01U (12 POSITION) RESIDING AT THE SPECIFIED SIGNAL HOUSE BASE STATION HOUSE LOCATION.

Bin Zhang  O10126 FIFTH EDITION  FIBER OPTIC OUTSIDE PLANT (OSP)  SCALE: NTS  RACK MOUNT  STANDARD DRAWING N					PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4514
REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP					2.01	Caltrain	12 POSITION FO DISTRIBUTION PANEL	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4514



FIFTH EDITION

DESCRIPTION

REV DATE BY CHK APP

010126

DATE BY CHK APP

PENINSULA CORRIDOR JOINT POWERS BOARD

DIRECTOR, ENGINEERING

Caltrain.

ENGINEERING STANDARD DRAWINGS CADD FILE NAME: SD-4

FIBER OPTIC OUTSIDE PLANT (OSP)


12 POSITION FO DISTRIBUTION PANEL WALL MOUNT

SD-4515


SD-4515

STANDARD DRAWING NO.:

FIFTH





CLOSET CONNECTOR HOUSING



- 1. CLOSET CONNECTOR HOUSINGS SHALL BE INSTALLED IN FO DISTRIBUTION PANELS THAT USE PRE—CONNECTORIZED DROP ASSEMBLIES.
- 2. ADAPTERS SHALL BE SC STYLE, DUPLEX, UPC, 12 FIBER.
- 3. THE CONNECTOR HOUSINGS SHALL INSTALL ACCORDING TO THE MANUFACTURER'S PROCEDURES AND SPECIFICATIONS.
- 4. MANUFACTURER SHALL BE CORNING OR APPROVED EQUIVALENT. PART # CCH-CP12-6C.

		PENINSULA CORRIDOR JOINT POWERS BOARD	ENGINEERING STANDARD DRAWINGS CADD FILE NAME: SD-4516
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION	REV DATE BY CHK APP	Bin Zhang  DIRECTOR, ENGINEERING  APPROVED BY:  Califfai	FIBER OPTIC OUTSIDE PLANT (OSP)  12 POSITION CLOSET CONNECTOR HOUSING  REV: EDITION: FIFTH  SCALE: NTS STANDARD DRAWING NO.: SD-4516








LETTERING 1" NOMINAL

2 3/4" WT2

PCJPB FIBER OPTICS-A WW2 (FOR BUTT SPLICE LOCATIONS)



LOGO DETAIL


#### **PULL BOX NOTES:**


- 1. ALL NON-DELIBERATE TRAFFIC PULL BOXES & COVERS MUST COMPLY WITH ALL TEST PROVISIONS OF THE LATEST ANSI/SCTE 77 "SPECIFICATION FOR UNDERGROUND ENCLOSURE INTEGRITY", AND MUST MEET THE TIER 22 APPLICATION. MARKINGS SHOWING THE TIER 22 RATING MUST BE LABELED OR STENCILED ON THE INSIDE AND OUTSIDE OF THE BOX.
- 2. ALL NON-DELIBERATE TRAFFIC PULL BOXES AND COVERS MUST BE MADE OF POLYMER CONCRETE WITH FIBERGLASS REINFORCEMENT. THE BOX MUST HAVE CONTINUOUS FIBERGLASS CLOTH REINFORCEMENT ON THE INSIDE AND OUTSIDE PERIMETERS. THE COVERS MUST HAVE A MINIMUM OF TWO LAYERS OF FIBERGLASS CLOTH REINFORCEMENT.
- 3. ALL BOXES & COVERS SHALL BE QUAZITE.
- 4. ALL NON-DELIBERATE PULL BOXES AND COVERS MUST BE TESTED AND CERTIFIED, MEETING ALL TEST PROVISIONS OF THE ANSI/SCTE 77, "SPECIFICATIONS FOR UNDERGROUND ENCLOSURES INTEGRITY" BY AN UNDERWRITERS LABORATORIES (UL) 66WF.
- 5. COVER SHALL BE SECURED TO PULL BOX USING 1/2 HEX HEAD AUGER
- 6. ALL COVERS SHALL BE COMPLETE WITH A MOLDED LOGO AND QUAZITE MANUFACTURE'S NAME AND TIER RATING LOGO (NO GLUE IN LOGOS).
- 7. ALL COVER PULL SLOTS SHALL BE 1 X 4 & RATED FOR A MINIMUM OF 3,000 LBS OF PULL OUT STRENGTH.
- 8. FOR PULL BOXES LOCATED IN DELIBERATE VEHICLE TRAFFIC AREAS, H-20 RATED BOXES SHALL BE INSTALLED. FOLLOW CALTRAIN SPECIFICATION SECTION 33 71 19.14 "CONCRETE HANDHOLES AND PULL BOXES" AND STANDARD DRAWING SD-5123 "SIGNAL AND COMMUNICATIONS GENERAL SIGNAL PULL BOX".


		PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4517
		APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH
		Bin Zhang	Caltrain.	PULL BOX DETAILS	SCALE: NTS
O10126   FIFTH EDITION   REV DATE BY CHK APP   DESCRIPTION   RE	EV DATE BY CHK APP	DIRECTOR, ENGINEERING		SHEET 1 OF 2	STANDARD DRAWING NO.: SD-4517

-QUAZITE LOGO

CADD FILE I	NAME: SD-4517				
REV:	EDITION: FIFTH				
SCALE:					
STANDARD	DRAWNG NO.: SD-4517				








# CONDUIT INSTALL SECTION DETAIL NOT TO SCALE

- 1. BOTTOM OF TRENCH SHALL BE CLEAN, SMOOTH, AND FREE OF ROCKS AND DEBRIS. A 2" LAYER OF SAND SHALL BE PLACED IN THE BOTTOM OF THE TRENCH PRIOR TO PLACING CONDUIT. AFTER PLACING CONDUIT IN THE TRENCH AND ALIGNING CONDUIT, BACKFILL TRENCH WITH SAND AND COMPACT AT EVERY 6" LIFT INTERVALS UNTIL 18" ABOVE THE CONDUIT. AFTER 18" ABOVE THE CONDUIT, COMPACT THE REMAINING 6" AND 24" LIFT INTERVALS WITH THE NATIVE EXCAVATED MATERIAL OR OTHER MATERIAL ACCEPTABLE TO CALTRAIN TRENCHING AND BACKFILLING SHALL BE IN ACCORDANCE WITH CALTRAIN SPECIFICATION SECTION 31 00 00 "EARTHWORK".
- 2. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO PREPARE TRENCH SO THAT THE CONDUIT IS STRAIGHT AND TRUE AS POSSIBLE TO ALLOW FOR EXTENDED UNINTERRUPTED PULLS OF INNER DUCTS AND FIBER OPTIC CARLES
- 3. SURFACE TO BE RESTORED TO ORIGINAL CONDITION TO THE SATISFACTION OF CALTRAIN.
- 4. WHEN CROSSING TRACKS WITH CONDUIT, THE CONTRACTOR SHALL FOLLOW CALTRAIN STANDARD DRAWING SD-8001 "PIPELINES FOR NON-FLAMMABLE SUBSTANCES ACROSS / ALONG ROW.
- 5. WHEN PLACING CONDUITS UNDER ROAD CROSSINGS, THE CONTRACTOR SHALL USE CASINGS AS DESCRIBED IN CALTRAIN STANDARD DRAWING SD-8001. THE CONTRACTOR SHALL ADHERE TO CALTRANS AND THE APPROPRIATE CITY AND / OR MUNICIPALITY SPECIFICATIONS.
- 6. PHOTOS ARE RECOMMENDED AS A RECORD TO DOCUMENT RECONSTRUCTION AND POST RESTORATION CONDITIONS.

			PENINSULA CORRIDOR JOINT PO	WERS BOARD	<b>ENGINEERING STANDARD DRAWINGS</b>	cadd file name: SD-4519
			APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH
			Bin Zhang	Caltrain.	UNDERGROUND TRENCH DETAILS	SCALE:
010126	FIFTH EDITION					STANDARD DRAWING NO.:
REV DATE BY	CHK APP DESCRIPTION	REV DATE BY CHK APP	DIRECTOR, ENGINEERING			SD-4519




#### NOTES:

- (1) VERTICAL DIMENSIONS TYPICAL FOR CASINGS
- (2) WITH CURB: 6' STATE & 2' CITY ROADS MINIMUM WITHOUT CURB: 8' STATE & 4' CITY ROADS MINIMUM
- (3) STEEL CASING PIPE SHALL CONFORM TO THE REQUIREMENTS OF (COOPER E-80) RAILWAY LOADING.
- (4) BORES CROSSING TRACKS SHALL ADHERE TO THE CALTRAIN STANDARD DRAWING SD-8001 'PIPELINES FOR NON-FLAMMABLE SUBSTANCES ACROSS/ALONG
- (5) BORE DEPTH FOR LAND FILL AREAS MAY BE ADJUSTED TO ACCOMMODATE FIELD CONDITIONS.
- (6) CONDUIT TYPE FOR TRACK CROSSINGS SHALL BE THE FOLLOWING:
  4" STEEL CASING PIPE
  6" STEEL CASING PIPE

TRACK CROSSING		
MINIMUM CASING SIZE AND THICKNESS		
STEEL CASING PIPE TRADE SIZE	4.00"	6.00"
STEEL CASING PIPE I.D.	4.050"	6.093"
STEEL CASING PIPE O.D.	4.500"	6.625"
STEEL CASING PIPE WALL THICKNESS	0.188"	0.188"

STEEL CASING BORE DETAIL (UNDER TRACK)

	PENINSULA CORRIDOR JOINT POW	ERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4520
	Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  TYPICAL BORE DEȚAIL	REV: EDITION: FIFTH  SCALE: NTS
O10126   FIFTH EDITION	DIRECTOR, ENGINEERING		(UNDER TRACK)	STANDARD DRAWING NO.: SD-4520




- (1) VERTICAL DIMENSIONS TYPICAL FOR CASINGS
- (2) WITH CURB: 6' STATE & 2' CITY ROADS MINIMUM WITHOUT CURB: 8' STATE & 4' CITY ROADS MINIMUM
- (3) PVC/STEEL CASING PIPE SHALL CONFORM TO THE REQUIREMENTS OF (COOPER E-80) RAILWAY LOADING.
- (4) ROAD CROSSING BORES DEPTHS SHALL ADHERE CALTRANS "ENCROACHMENT PERMITS MANUAL SECTION 600" OR THE CITY/MUNICIPALITY CONSTRUCTION REQUIREMENTS.
- (5) BORES ALONG ROW SHALL ADHERE TO THE CALTRAIN STANDARD DRAWING SD-8001 'PIPELINES FOR NON-FLAMMABLE SUBSTANCES ACROSS/ALONG
- (6) BORE DEPTH FOR LAND FILL AREAS MAY BE ADJUSTED TO ACCOMMODATE FIELD CONDITIONS.
- (7) CONDUIT TYPE FOR STREET CROSSINGS SHALL BE THE FOLLOWING:
   4" STEEL CASING PIPE OR 4" PVC (SCH 80) BORE-GUARD
   6" STEEL CASING PIPE OR 6" PVC (SCH 40) BORE-GUARD
- (8) UTILIZE EXISTING PVC (SCH 80) SPARE CONDUIT CROSSING STREET WHERE AVAILABLE.

STREET CROSSING (BORE DEPTH GREATER THAN 10')										
MINIMUM CASING SIZE AND THICKNESS										
PVC CASING PIPE TRADE SIZE	4.00"	6.00"								
PVC CASING PIPE I.D.	4.00"	6.00"								
PVC CASING PIPE O.D.	4.500"	6.625"								
PVC CASING PIPE WALL THICKNESS	0.250"	0.280"								

STREET CROSSING (BORE DEPTH 10' OR LESS)										
MINIMUM CASING SIZE AND THICKNESS										
STEEL CASING PIPE TRADE SIZE	4.00"	6.00"								
STEEL CASING PIPE I.D.	4.050"	6.093"								
STEEL CASING PIPE O.D.	4.500"	6.625"								
STEEL CASING PIPE WALL THICKNESS	0.188"	0.188"								

PVC/STEEL CASING BORE DETAIL (STREET CROSSING)

						PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4521
01012 REV DATE	FIFTH EDITION	DESCRIPTION	REV DATE	BY CHK	APP	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  TYPICAL BORE DETAIL (STREET CROSSING)	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4521



ASPHALT TRENCH AND BACKFILL DETAIL

NOT TO SCALE


UW - WIDTH OF UTILITY


CLR - CLEARANCE BETWEEN PRODUCT AND TRENCH WALL

CLSM — CONTROLLED LOW STRENGTH MATERIAL

HMA - HOT MIX ASPHALT

TW - TRENCH WIDTH






NOTES:

NOT TO SCALE

- 1. STRUCTURE BACKFILL SHALL CONFORM TO SECTION 19 3.06 OF CALTRANS STANDARD SPECIFICATIONS.
- 2. SLURRY CEMENT, IF USED, BACKFILL SHALL CONFORM TO SECTION 19 3.062 OF CALTRANS STANDARD SPECIFICATIONS.
- 3. HMA SHALL CONFORM TO SECTION 39 OF CALTRANS STANDARD SPECIFICATIONS.
- 4. ALL METHODS OF COMPACTION SHALL BE BY MECHANICAL MEANS.
- 5. AGGREGATE BASE SHALL CONFORM TO SECTION 26 OF THE CALTRANS STANDARD SPECIFICATIONS.
- 6. ALL WORK SHALL BE AS AUTHORIZED BY THE APPROVED ENCROACHMENT PERMIT PLANS, AND/OR AS DIRECTED BY THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE.
- 7. WHEN THE UW IS  $\geq$  6" THEN THE MINIMUM CLR SHALL BE 6".
- 8. COLD PLANING AND RE—SURFACING OVERLAY SHALL BE PARALLEL TO THE ROADWAY AND TO THE NEAREST LANE LINE FOR THE ENTIRE LENGTH OF THE TRENCH/DISTURBED AREAS, AND/OR DIRECTED BY THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE.
- 9. WHEN COLD PLANING IS REQUIRED, THE MINIMUM SHALL BE 0.10" OR AS DIRECTED BY THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE TO ACCOMMODATE FIELD CONDITIONS.
- 10. COLD PLANING MAY BE REQUIRED AT THE DIRECTION OF THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE TO ACCOMMODATE THE PLACEMENT OF STEEL PLATES.
- 11. WHEN TRENCH PLACEMENT IS WITHIN 4' OF CURB AND GUTTER, ADDITIONAL COLD PLANING MAY BE REQUIRED AT THE DISCRETION OF THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE.
- 12. ANY PAVEMENT MARKINGS AND/OR STRIPING REMOVED OR DAMAGED DURING CONSTRUCTION SHALL BE REPLACED AS DIRECTED BY THE STATE'S OR MUNICIPALITY'S REPRESENTATIVE.
- 13. A TRACER WIRE SHALL BE PLACED WITHIN THE CONDUIT AS SHOWN.
- 14. A PAINT BINDER (TACK COAT) OF ASPHALT TIC EMULSION CONFORMING TO SECTION 39-4.02, PRIME COAT & PAINT BINDER (TACK COAT) SHALL BE FURNISHED AND APPLIED.
- 15. NEW PAVEMENT BASE SHALL CONSIST OF EITHER CL.II AGGREGATE BASE, 2—SACK SLURRY CEMENT, OR CLSM. WHEN TW IS  $\leq$  24",CL.II AGGREGATE BASE IS NOT RECOMMENDED FOR BACKFILL.
- 16. NEW SUBGRADE SHALL CONSIST OF EITHER CL.II AGGREGATE BASE, 2—SACK SLURRY CEMENT, OR CLSM. WHEN TW IS ≤ 24",CL.II AGGREGATE BASE IS NOT RECOMMENDED FOR BACKFILL.
- 17. A WARNING TAPE SHALL BE PLACED AT THE TOP OF THE NEW SUBGRADE MATERIAL.
- 18. PHOTOS ARE RECOMMENDED AS A RECORD TO DOCUMENT PRECONSTRUCTION AND POST RESTORATION CONDITIONS.


	PENINSULA CORRIDOR JOINT POV	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4522
	Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  TYPICAL ASPHALT AND CONCRETE	REV: EDITION: FIFTH  SCALE: NTS
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	DIRECTOR, ENGINEERING	•	TRENCH DETAIL	STANDARD DRAWING NO.: SD-4522




EXISTING SIGNAL HOUSE / CASE

- ENSURE CONDUIT ENTRANCES INTO EACH HOUSE OR CASE USING LB COUPLERS ARE APPROVED BEFORE PROCEEDING WITH CONSTRUCTION.
- 2. SUBMIT SHOP DRAWINGS OF WHERE ENTRANCES ARE TO BE LOCATED BEFORE PROCEEDING WITH CONSTRUCTION.
- 3. FOLLOW MATERIAL MANUFACTURERS' PROCEDURES AND PRACTICES.
- 4. FOLLOW CALTRAIN STANDARD SPECIFICATION SECTION 02300 "EARTHWORKS".
- 5. SURFACE AREA TO BE RESTORED TO ORIGINAL CONDITION TO THE SATISFACTION OF CALTRAIN.
- 6. EXPOSED CONDUIT AND COUPLINGS SHALL BE VANDAL RESISTANT.
- 7. OUTSIDE WALL ENTRY SHALL BE USED ONLY IF THE PREFERRED CABLE CHUTE/FLOOR ENTRY IS NOT FEASIBLE.

					PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4523
					Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH  SCALE: NTS
R	010126 EV DATE BY	CHK APP	FIFTH EDITION  DESCRIPTION	REV DATE BY CHK APP	DIRECTOR, ENGINEERING	B	CONDUIT OUTCIDE WALL ENTRY	STANDARD DRAWING NO.: SD-4523




EXISTING SIGNAL HOUSE / CASE (FO BACKBONE-SAME SIDE)




# EXISTING SIGNAL HOUSE / CASE (FO BACKBONE-OPPOSITE SIDE)

- ENSURE EXISTING SIGNAL CONDUIT HAS ADEQUATE ROOM FOR FO DROP CABLE AND IS APPROVED FOR USE BEFORE PROCEEDING WITH CONSTRUCTION.
- 2. INSTALL FO DROP CABLE IN THE EXISTING SIGNAL CONDUIT THAT IS NEAREST TO THE HOUSE / CASE CORNER BEHIND THE EQUIPMENT BACKBOARD.
- 3. ONCE THE FO DROP CABLE IS INSTALLED, SEAL CONDUIT.
- 4. FOLLOW MATERIAL MANUFACTURERS' PROCEDURES AND PRACTICES.
- 5. FOLLOW CALTRAIN STANDARD SPECIFICATION SECTION 02300 "EARTHWORKS" FOR TRENCHING AND BORING.
- 6. SURFACE AREA TO BE RESTORED TO ORIGINAL CONDITION.

	PENINSULA CORRIDOR JOINT PO	<b>ENGINEERING STANDARD DRAWINGS</b>	cadd file name: SD-4524	
26 FIFTH EDITION	Bin Zhang	Caltrain.	TYP HOUSE & CASE CONDUIT ENTRY	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.:




EXISTING SIGNAL HOUSE / CASE (FO BACKBONE-SAME SIDE)




## EXISTING SIGNAL HOUSE / CASE (FO BACKBONE-OPPOSITE SIDE)

- 1. ENSURE EXISTING CABLE CHUTE HAS ADEQUATE ROOM FOR FO DROP CONDUIT AND IS APPROVED FOR USE BEFORE PROCEEDING WITH CONSTRUCTION.
- 2. INSTALL 2" (SCH 40) RIGID PVC CONDUIT "STUD UP" AND 90° SWEEP. GROUT AND SEAL CONDUIT ENTRY. INSTALL TERMINAL ADAPTER WITH LOCK NUT AND BUSHING AND SEAL CONDUIT AFTER FO DROP CABLE IS INSTALLED.
- 3. INSTALL CONDUIT IN EXISTING CABLE CHUTE AS FAR FROM DOORWAY AS PRACTICABLE.
- 4. FOLLOW MATERIAL MANUFACTURERS' PROCEDURES AND PRACTICES.
- 5. FOLLOW CALTRAIN STANDARD SPECIFICATION SECTION 02300 "EARTHWORKS" FOR TRENCHING AND BORING.
- 6. SURFACE AREA TO BE RESTORED TO ORIGINAL CONDITION.


	PENINSULA CORRIDOR JOINT POWE	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4525	
010126 FIFTH EDITION	Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  TYP HOUSE & CASE CONDUIT ENTRY  (USING NEW INFRASTRUCTURE)	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4525








GROUNDING REQUIREMENTS FOR TYPICAL UTILITY COMPANY POLE INSTALLATION


APPROVED BY:  Bin Zhang  GROUNDING REQUIREMENTS FOR  SCALE:	PENINSULA CORRIDOR JOINT POWERS BOARD		ENGINEER	RING STANDARD	<b>DRAWINGS</b>	CADD FILE NAM	ame: SD-4527	
		Y:		FIBER OF	TIC OUTSIDE PLA	ANT (OSP)	REV: EI	EDITION: FIFTH
FIETH FOITION ONCOUNTE TO		ang	Caltrain <sub>®</sub>				SCALE: STANDARD DRA	NTS

















11												CADD FILE NAME:
									PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	SD-4533
									APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	
	010	126	FIFTH EDITION						oin shang	Caltrain.	BRIDGE ATTACHMENT (TYP D) ATTACHMENT INSIDE STEEL FLANGE	SCALE:  NTS  STANDARD DRAWING NO.:
Ш	REV DA		APP	DESCRIPTION	REV [	DATE	BY CHK	APP	DIRECTOR, ENGINEERING		7,117,0111112111 11101DE 01EEE 1E/1110E	SD-4533



**ENGINEERING STANDARD DRAWINGS** PENINSULA CORRIDOR JOINT POWERS BOARD SD-4534 FIBER OPTIC OUTSIDE PLANT (OSP) FIFTH Caltrain. SCALE: BRIDGE ATTACHMENT (TYP E) ATTACHMENT CONCRETE BASE NTS FIFTH EDITION 010126 TANDARD DRAWING NO.: SD-4534 DIRECTOR, ENGINEERING DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP





# **TUNNEL DISTANCES:**


- \* TUNNEL #1 1,796'
- \* TUNNEL #2 1,086'
- \* TUNNEL #3 2,362' \* TUNNEL #4 - 3,545'

# NOTES:


NORTH PORTAL TYPICAL TUNNEL ENTRANCE

- 1. MATERIAL AND PROPOSED LOCATION SHALL BE APPROVED BEFORE PROCEEDING WITH CONSTRUCTION.
- 2. FOLLOW MATERIAL MANUFACTURERS' PROCEDURES AND PRACTICES.
- 3. FOLLOW CALTRAIN STANDARD SPECIFICATION SECTION 02300 "EARTHWORKS" FOR ANY EXCAVATIONS MADE DURING INSTALLATION.
- 4. SURFACE AREA TO BE RESTORED TO ORIGINAL CONDITION.
- 5. FOR UNDERGROUND CONDUIT PLACEMENT REFER TO DWG SD-4520 "UNDERGROUND TRENCH DETAIL" AND DWG SD-4521 "TYPICAL BORE DETAIL".
- 6. SEE DWG SD-4536 FOR ATTACHMENT DETAILS.
- 7. HAND TRENCH ONLY WITHIN 50 FEET OF TUNNEL ENTRANCE.
- 8. SEE DWG SD-4536 FOR ATTACHMENT DETAIL.

	PENINSULA CORRIDOR JOINT PO	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4535	
	APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITION: FIFTH
010126 FIFTH EDITION	oin shang	Caltrain <sub>®</sub>	FIBER OPTIC CABLE BACKBONE TUNNEL ATTACHMENT	SCALE: NTS
DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	DIRECTOR, ENGINEERING		DACROONE TOWNER ATTACHMENT	STANDARD DRAWING NO.: SD-4535



ENGINEERING STANDARD DRAWINGS PENINSULA CORRIDOR JOINT POWERS BOARD SD-4536 FIBER OPTIC OUTSIDE PLANT (OSP) FIFTH Caltrain. SCALE: TYPICAL FIBER OPTIC NTS FIFTH EDITION BACKBONE TUNNEL ATTACHMENT 010126 STANDARD DRAWING NO.: SD-4536 DIRECTOR, ENGINEERING DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP




TUNNEL 4


(MOST RESTRICTED CLEARANCE OF ALL TUNNELS)

LOOKING NORTH
NOT TO SCALE

LOOKING SOUTH NOT TO SCALE

	PENINSULA CORRIDOR JOINT POWE	ENGINEERING STANDARD DRAWINGS	cadd file name: SD-4537	
	Bin Zhang	Caltrain	FIBER OPTIC OUTSIDE PLANT (OSP)  TUNNEL CONDUIT CLEARANCE	REV: EDITION: FIFTH  SCALE: NTS
O10126   FIFTH EDITION   REV DATE BY CHK APP   DESCRIPTION   REV DATE BY CHK APP	DIRECTOR, ENGINEERING			STANDARD DRAWING NO.: SD-4537






- 1. CORE DRILL HOLE SIZE SHALL BE 6".
- 2. PLACE 5" GALVANIZED STEEL SLEEVE EXTENDING 1" OUT OF CONCRETE.
- 3. PLACE 3" RGS CONDUIT THROUGH SLEEVE AND GROUT EDGE OF CORE HOLE AND BETWEEN SLEEVE AND 3" RGS CONDUIT.
- 4. WHEN DRILLING CAUTION SHALL BE USED AS NOT TO DAMAGE EXISTING REBAR. X—RAY OR DRILL PILOT HOLE TO LOCATE EXISTING REBARS.

							PENINSULA CORRIDOR JOINT PO	WERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-	E: 1—4539
				+			APPROVED BY:		FIBER OPTIC OUTSIDE PLANT (OSP)	REV: EDITIO	TION: FIFTH
							Bin Zhang	Caltrair.	ABUTMENT / WINGWALL	SCALE:	NTS
REV DATE	CHK APP	FIFTH EDITION	DESCRIPTION	REV	/ DATE	BY CHK APP	DIRECTOR, ENGINEERING		CORE DRILL DETAILS	STANDARD DRAWN	MING NO.: 0-4539

# OTDR Fiber Test Standards for Single Mode Fiber

# OTDR Fiber Test Scenario and recommended tests



- Test Plan would create test procedures to test new splice points
- Testing splice point (1) from existing fiber node B and adjacent northern fiber node
- Testing splice point (2) from existing fiber nodes A and C
- Testing splice point (3) from existing fiber nodes B and D
- Testing splice point (4) from existing fiber node C and adjacent southern fiber node
- Number of tests and corresponding locations varies and dependent on location of new splices
- Potentially test multiple splice points on a single strand by selecting fiber nodes encompassing all points then analyze test results to differentiate points

OTDR Fiber Testing Standards Single Mode Fiber


- 1. All cables shall be OTDR tested at 1310 nm and 1550 nm (for single mode) operating wavelengths for anomalies and to ensure uniformity of cable attenuation and connector insertion loss.
- 2. OTDR tests shall be performed utilizing a pulse suppressor such that the FDP termination shall be shown.
- 3. All OTDR testing procedures and field test instruments shall comply with applicable requirements of:

a. TIA 455-78

b. TIA 455-133

- 4. Each fiber link and channel shall be tested in bi-directionally.
- 5. A launch cable shall be installed between the OTDR and the first link connection.
- 6. A receive cable shall be installed after the last link connection.
- 7. Optical Return Loss (ORL) for each link shall be measured.
- 8. Fiber Length shall be measured
- 9. Test Results:
  - a. Reflective events shall not exceed -40 dB
  - b. Connections shall not exceed 0.75 dB of attenuation
  - c. Non-reflective events (splices) shall not exceed 0.3 db
  - d. Point discontinuities shall not exceed 0.1 db
  - e. ORL shall be less than -30 dB

	PENINSULA CORRIDOR JOINT POWERS BOA	RD ENGINEERING STANDARD DRAWINGS CADD FILE NAME: SD-4540
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION REV DATE BY CHK APP	Bin Zhang  DIRECTOR, ENGINEERING  APPROVED BY:  Calif	FIBER OPTIC OUTSIDE PLANT (OSP)  OTDR FIBER TESTING STANDARDS FOR FIBER SINGLE MODE  REV: EDITION: FIFTH  SCALE: NTS STANDARD DRAWING NO.: SD-4540



# NOT USED

			+		+
010126		FIFTH EDITION			

PENINSULA CORRIDOR JOINT POWERS BOARD





STATION COMMUNICATIONS SUPPORTING SYSTEM AND OTHERS

ENGINEERING STANDARD DRAWINGS CADD FILE NAME: SD-4 SD-4802

SD-4802

STANDARD DRAWING NO.:





### NOTES:

- 1. OUTDOOR DISTRIBUTION CABINET SHALL HAVE SIDE MOUNTED AC UNIT. REFER TO DIVISION 17 SPECIFICATIONS FOR STANDARDS.
- 2. INSTALL TWO 120 VAC DUPLEX RECEPTACLES. ONE L5-30 FOR UPS ESSENTIAL POWER AND THE OTHER L5-15 FOR NONESSENTIAL POWER. RECEPTACLES ARE NOT SHOWN FOR CLARITY.
- 3. CONNECT VERTICAL AC STRIP TO L5-30A, 120VAC UPS CIRCUIT. STRIP INCLUDES (10) NEMA5-20P RECEPTACLES.

# KEY:

- 19" EQUIPMENT RACK.
- FIBER DISTRIBUTION PANEL.
- WIRE MANAGEMENT.
- CAT 6A PATCH PANEL WITH SURGE PROTECTION DEVICE.
- LAN ETHERNET SWITCH #1.
- LAN ETHERNET SWITCH #2.
- CLIPPER ETHERNET SWITCH WITH SFP UPLINK PORTS.
- CLIPPER POWER SUPPLY AND FUSES.
- UPS.
- UPS BATTERIES.
- RACK GROUND BUS BAR.


DISTRIBUTION CABINET, VERTICAL PROFILE **ELEVATION** SCALE: NTS


REV	DATE	СНК	FIFTH EDITION	DESCRIPTION	REV	DATE	BY	CHK APF	
	010126		FIETH EDITION						


PENINSULA CORRIDOR JOINT POWERS BOARD DIRECTOR, ENGINEERING





<b>ENGINEERING STANDARD DRAWINGS</b>	CADD FILE	NAME: SD-4804
STATION COMMUNICATIONS	REV:	EDITION: FIFTH
SUPPORTING SYSTEM AND OTHERS DISTRIBUTION CABINET	SCALE:	NTS
VERTICAL PROFILE	STANDARD	drawing no.: SD-4804
















FIFTH





- SUBSYSTEM. THIS DIVERSE PATHWAY WILL ALLOW NETWORK REDUNDANCY FOR THOSE DEVICES WITH INTEGRATED NETWORK SWITCHING (FUTURE).
- 3. DEVICE QUANTITIES WILL VARY WITH STATION SIZE AND SUBSYSTEM TYPE.
- 4. REFER TO STATION CONDUIT RISER PLANS.
- 5. REFER TO SD-4201 FOR CMS TERMINATION. REFER TO SD-4210 FOR SPEAKERS TERMINATION. REFER TO SD-4301 FOR CCTV TERMINATION. REFER TO SD-4401 FOR TVM TERMINATION. REFER TO SD-4109 FOR CID.

1" GRS CONDUIT, FUTURE NETWORK DIVERSITY


1" GRS CONDUIT, WITH CABLE, HOME RUN FROM DC PER DEVICE

SUBSYSTEM DEVICE WITH JUNCTION BOX (TVM, VMS, CCTV)

		PENINSULA CORRIDOR JOINT POWE	ERS BOARD	ENGINEERING STANDARD DRAWINGS	CADD FILE NAME: SD-4835
O10126 FIFTH EDITION  REV DATE BY CHK APP DESCRIPTION	REV DATE BY CHK APP	Bin Zhang  DIRECTOR, ENGINEERING	Caltrain	STATION COMMUNICATIONS SUPPORTING SYSTEM AND OTHERS SUBSYSTEM DEVICE CONDUIT SCHEME	REV: EDITION: FIFTH  SCALE: NTS  STANDARD DRAWING NO.: SD-4835

## NOTES:


- 1. PROVIDE SOLID STATE SURGE PROTECTOR AT 66-BLOCK WHEN CROSS-CONNECTING ALARMS TO ANOTHER EQUIPMENT OR SIGNAL HOUSE. PROVIDE GROUNDING PER DIVISION 17 SPECIFICATIONS.
- 2. ADDITIONAL ALARM POINTS CAN BE ADDED AS REQUIRED.
- 3. ALARM WIRING SHALL BE 1-PAIR, #22 AWG SOLID CONNECTOR.



NOTE: PARALLEL ALL EQUIPMENT MAJOR ALARM POINTS AND WIRE TO 66 BLOCK. TO 66 BLOCK MAJOR ALARM TO NEXT EQUIPMENT ALARM(N/O) ALARM(N/0)

NETWORK EQUIP

NETWORK EQUIP




WALL MOUNTED 66-TYPE **BLOCK AT MAIN** DISTRIBUTION FRAME (MDF)

											F
	010126				FIFTH EDITION						
REV	DATE	BY	СНК	APP	DESCRIPTION	REV	DATE	BY	СНК	APP	


PENINSULA CORRIDOR JOINT PO	WERS BOARD
APPROVED BY:	
Bin Zhang  DIRECTOR, ENGINEERING	Caltrai



ENCINEEDING STANDARD DRAWIN	CADD FILE	NAME:
ENGINEERING STANDARD DRAWIN	165	SD-4850
STATION COMMUNICATIONS	REV:	EDITION: FIFTH
SUPPORTING SYSTEM AND OTHER EQUIPMENT AND SECURITY ALARM	. —	NTS
DEMARCATION	STANDARD	DRAWING NO.: SD-4850




# CELING MOUNTED VMS INSTALLATION DETAIL — FRONT VIEW SCALE: NTS




VMS SIGN

DETAIL — TOP VIEW

SCALE: NTS








# NOTES:

- 1. PROVIDE NEOPRENE WATER RESISTANT GASKET 1/16" THICK MINIMUM BETWEEN THE PLATE AND SIGN. GASKET TO MATCH PLATE DIMENSIONS AND HOLE PATTERN.
- 2. PROVIDE SUN SHIELD FOR THE SIGN.
- 3. PROVIDE BIRD DETERRENT.
- 4. THE HEIGHT OF THE NEW SIGN AS MEASURED FROM THE PLATFORM TO THE BOTTOM SIDE OF THE SIGN SHALL BE WITHIN +/-2" OF THAT FOR THE EXISTING SIGN BUT NO GREATER THAN 9 FEET.



PENINSULA CORRIDOR JOINT POWERS BOARD **ENGINEERING STANDARD DRAWINGS** SD-4901 STATION COMMUNICATIONS FIFTH Caltrain. COMMUNICATIONS EQUIPMENT SCALE: VARIABLE MESSAGE SIGN BOARD FIFTH EDITION 010126 CEILING MOUNT TANDARD DRAWING NO.: SD-4901 REV DATE BY CHK APP DIRECTOR, ENGINEERING DATE BY CHK APP DESCRIPTION

# NOT USED

	010126			FIFTH EDITION	1				
REV	DATE	BY	СНК	DESCRIPTION	REV	DATE	BY CHK	APP	

PENINSULA CORRIDOR JOINT POWERS BOARD



STATION COMMUNICATIONS COMMUNICATIONS EQUIPMENT

ENGINEERING STANDARD DRAWINGS

SD-4902 FIFTH SCALE:

SD-4902

STANDARD DRAWING NO.:

